

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR**

WEIRTON AREA WATER BOARD, WV3300516

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 1/1/2026 and 1/31/2026, we failed to maintain turbidity levels less than or equal to 0.3 NTU for a least 95% of the monthly readings and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
44, MONTHLY COMB FLTR EFFLUENT (IESWTR/LT1) TURBIDITY Failure to Maintain Turbidity Below 0.3 NTU For At Least 95% of measurements	1/1/2026 to 1/31/2026

What happened? What is being done? (Describe corrective action)

While the clearwell was being cleaned as part of the upgrade construction, 12 turbidity readings were over 0.3 NTU in the month of January. This is no longer an issue.

For more information, please contact Weirton Water Treatment Plant at 304-797-8566
(Contact name) (Phone number)
or 3031 Birch Dr. Weirton WV 26062
(Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **WEIRTON AREA WATER BOARD**

State Water System ID #: WV3300516

Date Distributed: 5/4/2026